

No. F. 5(22)/AE/DWS/KSD/KMP/ 347
Government of Tripura
Office of the Assistant Engineer
DWS Sub-Division, Kamalpur, Dhalai Tripura

Dated, Kamalpur, 03/07/2026.

Name of Habitation/Location: Salema Class XII school, Salema, Kamalpur, Dhalai Tripura.

Sample Supplied By: Sanjib Das, Vice-Principal, Salema Class XII school.

Source of Sample: Delivery Point (SWTP)

Date of Collection: 01.07.2026

Date of Received: 02.07.2026

Date of Testing: 02.07.2026 onward.

Sl. No	Characteristic	BIS Acceptable limit	BIS Permissible limit	Result	Remark
1	Temperature (in °C)			32.6	
2	Odour	Agreeable	-	Agreeable	
3	Taste	Agreeable	-	Agreeable	
4	Turbidity (in NTU)	1	5	0.32	
5	pH value	6.5-8.5	No relaxation	7.58	
6	Total Hardness (as CaCO ₃)	200	600	--	
7	Iron (as Fe)	1.0	No relaxation	0.087	
8	Residual free Chlorine (as Cl)	0.2	1.0	0.0	
9	Total dissolved solids	500	2000	63.2	
10	Alkalinity (as CaCO ₃)	200	600	--	
11	Calcium (as Ca)	75	200	--	
12	Magnesium (as Mg)	30	100	--	
13	Total coliform bacteria	Shall not be detectable in any 100 ml sample		0	
14	Fecal coliform bacteria	Shall not be detectable in any 100 ml sample		--	

All units are in mg/l, mentioned otherwise.

Analysed by

[Signature]
04/7/26

Sr. Research Assistant
Sub-Division Level Water Testing Laboratory
Kamalpur Dhalai Tripura

Laboratory-In-Charge:

[Signature]
4/7/26

Junior Engineer
DWS Sub-Division, Kamalpur
Dhalai Tripura.

[Signature]
4/7/26

Assistant Engineer
DWS Sub-Division, Kamalpur
Dhalai Tripura.

GOVERNMENT OF TRIPURA
OFFICE OF THE MEDICAL OFFICER- IN-CHARGE
SALEMA PHC
SALEMA, DHALAI, TRIPURA.
Email: - phcsalema@gmail.com

F_1(02)/SLM/PHC/MOIC/2025-2026/D- 250-202 Date: - 14/07/2026

TO WHOM IT MAY CONCERN

This to certify that the Health team of Salema PHC has done health Screening of Salema Class XII School once in a month and the RBSK team also has done health Screening once in a month.

Thanking you.

Medical officer in-charge
Salema PHC
Salema, Dhalai, Tripura.

Copy to-

- 1) The CMO Ambassa Dhalai Tripura for kind information
- 2) The SDMO Kamalpur Dhalai Tripura for kind information
- 3) The HM of salema class XII school Salema Dhalai Tripura for kind information.

for
MOIC
Medical officer in-charge
Salema PHC
Salema, Dhalai, Tripura.

MEDICAL OFFICER IN-CHARGE
Salema PHC
Salema, Dhalai Tripura

GOVERNMENT OF TRIPURA
OFFICE OF THE SALEMA GRAM PANCHAYAT
SALEMA RD BLOCK,DHALAI TRIPURA

To
The principal
Salema Class XII School (Vidyajyoti)
Salema, Dhalai, Tripura

Subject- Certificate of Hygiene ,sanitation and water
supply of salema class XII school

Ref.your letter No.F.1/Vice-Principal/SHSS/CBSE/2025/54 Dated-
02/07/2025

Sir,

With reference to your letter mentioned above ,it is certified that
the sanitation and water supply of Salema Class XII school is fully
hygienic.

Hence,there is no problem in getting CBSE affiliation in regard to
Salema Class XII School if the School education department takes
intiative during the year 2026-27.

2. 14/07/26
Yours faithfully
In-charge (RPM)
Salema Gram Panchayat,
Salema R.D. Block, Dhalai Tripura,